



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2518

Customer

Facility Name: Sunridge
Address: 1 Sunridge Dr.
Champion, PA 15622

Sample Collection

Date: 6/2/25
Time: 10:45 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:45 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	10:45 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:45 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2518

Customer

Facility Name: Sunridge
Address: 1 Sunridge Dr.
Champion, PA 15622

Sample Collection

Date: 6/2/25
Time: 10:45 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:45 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/2/25	10:45 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:45 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor