



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2085

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

|                |   | <b><u>Sample Collection</u></b>               |
|----------------|---|---|
| Facility Name: | Castle Ridge Apt.                       | Date: 6/17/25                                 |
| Address:       | 850 Baldwin St.<br>Pittsburgh, PA 15234 | Time: 4:23 PM<br>Method: Grab                 |
| Matrix:        | Recreational Water                      | <b><u>Sample Final Analysis</u></b>           |
| Source Type:   | Pool                                    | Date: 6/20/25<br>Time: 9:00 AM<br>Analyst: AS |

| <b><u>Accredited Analysis</u></b> | <b><u>Results</u></b> | <b><u>Reporting limit</u></b> | <b><u>Incubation Date/Time</u></b> | <b><u>Analyst</u></b> | <b><u>Method</u></b> |
|-----------------------------------|-----------------------|-------------------------------|------------------------------------|-----------------------|----------------------|
| Escherichia Coli:                 | Absent                | Absent                        | 6/18/25                            | 11:35 AM              | AH                   |
| Total coliforms:                  | 0/100mls              | 2/100mls                      | 6/18/25                            | 11:35 AM              | AH                   |
| Standard plate count:             | 0/ml                  | 200/ml                        | 6/17/25                            | 5:45 PM               | SL                   |

| <b><u>Field Analysis</u></b> | <b><u>Results</u></b> | <b><u>Reporting limit</u></b> | <b><u>Date/Time</u></b> | <b><u>Analyst</u></b> | <b><u>Method</u></b> |
|------------------------------|-----------------------|-------------------------------|-------------------------|-----------------------|----------------------|
| pH:                          | 7.4 SU                | 7.2 - 7.8 SU                  | 6/17/25                 | 4:23 PM               | SL                   |
| Chlorine:                    | 2.0 mg/l              | 1.0 - 5.0 mg/l                | 6/17/25                 | 4:23 PM               | SL                   |
| Turbidity:                   | 1 NTU                 | 1 - 2 NTU                     | 6/17/25                 | 4:23 PM               | SL                   |

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2085

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

|                |   | <b><u>Sample Collection</u></b>               |
|----------------|---|---|
| Facility Name: | Castle Ridge Apt.                       | Date: 6/17/25                                 |
| Address:       | 850 Baldwin St.<br>Pittsburgh, PA 15234 | Time: 4:23 PM<br>Method: Grab                 |
| Matrix:        | Recreational Water                      | <b><u>Sample Final Analysis</u></b>           |
| Source Type:   | Pool                                    | Date: 6/20/25<br>Time: 9:00 AM<br>Analyst: AS |

| <b><u>Accredited Analysis</u></b> | <b><u>Results</u></b> | <b><u>Reporting limit</u></b> | <b><u>Incubation Date/Time</u></b> | <b><u>Analyst</u></b> | <b><u>Method</u></b> |
|-----------------------------------|-----------------------|-------------------------------|------------------------------------|-----------------------|----------------------|
| Escherichia Coli:                 | Absent                | Absent                        | 6/18/25                            | 11:35 AM              | AH                   |
| Total coliforms:                  | 0/100mls              | 2/100mls                      | 6/18/25                            | 11:35 AM              | AH                   |
| Standard plate count:             | 0/ml                  | 200/ml                        | 6/17/25                            | 5:45 PM               | SL                   |

| <b><u>Field Analysis</u></b> | <b><u>Results</u></b> | <b><u>Reporting limit</u></b> | <b><u>Date/Time</u></b> | <b><u>Analyst</u></b> | <b><u>Method</u></b> |
|------------------------------|-----------------------|-------------------------------|-------------------------|-----------------------|----------------------|
| pH:                          | 7.4 SU                | 7.2 - 7.8 SU                  | 6/17/25                 | 4:23 PM               | SL                   |
| Chlorine:                    | 2.0 mg/l              | 1.0 - 5.0 mg/l                | 6/17/25                 | 4:23 PM               | SL                   |
| Turbidity:                   | 1 NTU                 | 1 - 2 NTU                     | 6/17/25                 | 4:23 PM               | SL                   |

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor