



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**                      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

**Facility Name:**                      *Bright Oaks*  
**Address:**                              *600 N. Branch Road*  
   *Oakdale, PA 15071*

**Sample Collection**

*Date:*                              6/17/25  
*Time:*                              8:36 AM  
*Method:*                              Grab

**Matrix:**                              *Recreational Water*  
**Source Type:**                      *Pool*

**Sample Final Analysis**

*Date:*                              6/20/25  
*Time:*                              9:00 AM  
*Analyst:*                              AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	4:30 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25	8:36 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/17/25	8:36 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	8:36 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM 1**

**Lab# 2059**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Bright Oaks*

*Date: 6/17/25*

*Address: 600 N. Branch Road*  
*Oakdale, PA 15071*

*Time: 8:36 AM*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 6/20/25*

*Source Type: Pool*

*Time: 9:00 AM*

*Analyst: AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
Escherichia Coli:	Absent	Absent	6/18/25 10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25 10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25 4:30 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
pH:	8.0 SU	7.2 - 7.8 SU	6/17/25 8:36 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/17/25 8:36 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25 8:36 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor