

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 464

Customer

Facility Name: Big Blue Swim School

Address: 20412 US Rt19

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 1:40 PM
Method: Grab

Sample Final Analysis

 Date:
 7/17/25

 Time:
 8:30 AM

 Analyst:
 AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 3:53 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|---------|--------|--|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 1:40 PM | ZR | DPD | |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 1:40 PM | ZR | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 1:40 PM | ZR | Visual | |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 464

Customer

Facility Name: Big Blue Swim School

Address: 20412 US Rt19

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/14/25
Time: 1:40 PM
Method: Grab

Sample Final Analysis

 Date:
 7/17/25

 Time:
 8:30 AM

 Analyst:
 AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/15/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/15/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/14/25 | 3:53 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method | |
|----------------|----------|-----------------|-----------|---------|---------|--------|--|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/14/25 | 1:40 PM | ZR | DPD | |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/14/25 | 1:40 PM | ZR | DPD | |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/14/25 | 1:40 PM | ZR | Visual | |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

andre Smith