



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-2**

**Lab# 239**

**Customer**

Facility Name: Northgate High School

Address: 589 Union Ave  
Pittsburgh, PA 15202

Matrix: Recreational Water

Source Type: Pool Shallow

**Sample Collection**

Date: 10/1/25

Time: 9:22 AM

Method: Grab

**Sample Final Analysis**

Date: 10/3/25

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/25	5:20 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/25	5:20 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/1/25	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/1/25	9:22 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/1/25	9:22 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/1/25	9:22 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor