

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 011

Customer				Sample Collection			
Facility Name:	Athletic Club	Carnegie Library c	of Homestead	Date:	7/14/25		
A	540 E + 404	•		Time:	3:03 PM		
Address:	510 East 10th Ave Munhall, PA 15120			Method:	Grab		
	Murinan, FA	3120	Sample Final Analysis				
Matrix:	Recreational Water			Date: 7/17/25		5	
				Time:	8:30 AM		
Source Type:	Pool			Analyst: AS		o de la companya de	
Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B	
Field Analysis	Results	Reporting limit	Da	te/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/14/25	3:03 PM	SL	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:03 PM	SL	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:03 PM	SL	Visual	

Sample comments

anobre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 011

Customer				Sample Collection			
Facility Name:	Athletic Club	Carnegie Library c	of Homestead	Date:	7/14/25		
A	540 E + 404	•		Time:	3:03 PM		
Address:	510 East 10th Ave Munhall, PA 15120			Method:	Grab		
	Murinan, FA	3120	Sample Final Analysis				
Matrix:	Recreational Water			Date: 7/17/25		5	
				Time:	8:30 AM		
Source Type:	Pool			Analyst: AS		o de la companya de	
Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	EB	SM 9222G	
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	EB	SM 9222B	
Standard plate count:	0/ml	200/ml	7/14/25	5:00 PM	EB	SM 9215B	
Field Analysis	Results	Reporting limit	Da	te/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/14/25	3:03 PM	SL	DPD	
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	3:03 PM	SL	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	3:03 PM	SL	Visual	

Sample comments

anobre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor