



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-1

Lab# 468

Customer

Facility Name: *Holiday Inn Express*
Address: *3936 Moreoever Blvd.*
Monroeville, PA 15146

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *12/16/25*
Time: *10:55 AM*
Method: *Grab*

Sample Final Analysis

Date: *12/19/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/17/25	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/17/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/16/25	3:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/16/25	10:55 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	12/16/25	10:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/16/25	10:55 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor