Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# **2597**

Customer

Facility Name:	*Woodland Hills Club*
Address:	*2799 Bingham Drive*
	Upper St. Claire, PA 15241
Matrix:	*Recreational Water*
Source Type:	*Deep End*

Sample Collection

Date:	*8/4/25*
Time:	*2:23 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/7/25*
Time:	*11:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	2:23 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:23 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# **2597**

Customer

Facility Name:	*Woodland Hills Club*
Address:	*2799 Bingham Drive*
	Upper St. Claire, PA 15241
Matrix:	*Recreational Water*
Source Type:	*Deep End*

Sample Collection

Date:	*8/4/25*
Time:	*2:23 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/7/25*
Time:	*11:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	2:23 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/4/25	2:23 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	2:23 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor