



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-12

Laboratory Analysis Report **Lab# 2455**

Customer

Facility Name: Rosslyn Farms
Address: 200 Rosslyn Rd
Carnegie, PA 15106

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/13/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 4:00 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 3:30 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 3:30 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/13/25 | 3:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/13/25 | 10:15 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/13/25 | 10:15 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/13/25 | 10:15 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-12

Laboratory Analysis Report **Lab# 2455**

Customer

Facility Name: Rosslyn Farms
Address: 200 Rosslyn Rd
Carnegie, PA 15106

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/13/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 4:00 PM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/13/25 | 3:30 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/13/25 | 3:30 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/13/25 | 3:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 8/13/25 | 10:15 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/13/25 | 10:15 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/13/25 | 10:15 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor