

Facility Name:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 214

<u>Customer</u> <u>Sample Collection</u>

Liberty Hills Date: 6/2/25

Time: 11:37 AM

Address: 100 Liberty Lane Method: Grab Freedom, PA 15042

Sample Final Analysis

Matrix: Recreational Water Date: 6/5/25

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Results **Reporting limit** Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 6/3/25 9:15 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 9:15 AM EΒ SM 9222B 200/ml 6/2/25 3:17 PM AΗ SM 9215B Standard plate count: 0/ml **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Fecal Streptococcus 0/100mls 2/100mls 6/3/25 11:30 AM AΗ SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
рН:	7.0 SU	7.2 - 7.8 SU	6/2/25	11:37 AM	ZR	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	11:37 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	11:37 AM	ZR	Visual	

Sample comments

andre Smith



Facility Name:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 214

<u>Customer</u> <u>Sample Collection</u>

Liberty Hills Date: 6/2/25

Time: 11:37 AM

Address: 100 Liberty Lane Method: Grab Freedom, PA 15042

Sample Final Analysis

Matrix: Recreational Water Date: 6/5/25

Source Type: Spa Time: 9:30 AM
Analyst: AS

Accredited Analysis Results **Reporting limit** Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 6/3/25 9:15 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 6/3/25 9:15 AM EΒ SM 9222B 200/ml 6/2/25 3:17 PM AΗ SM 9215B Standard plate count: 0/ml **Additional Analysis** Results Reporting limit **Analyst** Method **Incubation Date/Time** Fecal Streptococcus 0/100mls 2/100mls 6/3/25 11:30 AM AΗ SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
рН:	7.0 SU	7.2 - 7.8 SU	6/2/25	11:37 AM	ZR	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	11:37 AM	ZR	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	11:37 AM	ZR	Visual	

Sample comments

andre Smith