



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 383**

**Customer**

Facility Name: Hilton Garden Inn  
Address: 9600 University Blvd  
Pittsburgh, PA 15108

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/30/25  
Time: 8:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 7/3/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	EB	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	8:30 AM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	8:30 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	8:30 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 383**

**Customer**

Facility Name: Hilton Garden Inn  
Address: 9600 University Blvd  
Pittsburgh, PA 15108

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/30/25  
Time: 8:30 AM  
Method: Grab

**Sample Final Analysis**

Date: 7/3/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	7/1/25	11:30 AM	EB	SM 9222G
-------------------	--------	--------	--------	----------	----	----------

Total coliforms:	0/100mls	2/100mls	7/1/25	11:30 AM	EB	SM 9222B
------------------	----------	----------	--------	----------	----	----------

Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	EB	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	7/1/25	12:00 PM	AH	SM 9230C
---------------------	----------	----------	--------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	6/30/25	8:30 AM	AH	DPD
-----	--------	--------------	---------	---------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/30/25	8:30 AM	AH	DPD
-----------	----------	----------------	---------	---------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/30/25	8:30 AM	AH	Visual
------------	-------	-----------	---------	---------	----	--------

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor