



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 382

Customer

Facility Name: Hilton Garden Inn Moon

Address: 9600 University Blvd
Pittsburgh, PA 15108

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 1/29/26

Time: 10:50 AM

Method: Grab

Sample Final Analysis

Date: 1/31/26

Time: 5:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26 5:17 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26 5:17 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	1/29/26 5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	1/29/26 10:50 AM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	1/29/26 10:50 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/29/26 10:50 AM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)