



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**N-13**

**Lab# 2351**

**Customer**

**Facility Name:** Mews - Town North  
**Address:** Beech Court  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 6/16/25  
**Time:** 11:02 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/19/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	11:02 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	11:02 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	11:02 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
*Anaëe Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**N-13**

**Lab# 2351**

**Customer**

**Facility Name:** Mews - Town North  
**Address:** Beech Court  
Pittsburgh, PA 15237

**Sample Collection**

**Date:** 6/16/25  
**Time:** 11:02 AM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Pool

**Sample Final Analysis**

**Date:** 6/19/25  
**Time:** 10:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	11:02 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	11:02 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	11:02 AM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
*Anaëe Smith*