



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2318**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *LaVale*  
  
*Address:*            *140 Lavale Dr.*  
                              *Monroeville, PA 15146*

**Sample Collection**

*Date:*                    *8/12/25*  
*Time:*                *10:31 AM*  
*Method:*             *Grab*

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Pool*

**Sample Final Analysis**

*Date:*                    *8/15/25*  
*Time:*                *9:00 AM*  
*Analyst:*              *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	10:31 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:31 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:31 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaëe Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2318**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name: LaVale*  
*Address: 140 Lavale Dr.*  
*Monroeville, PA 15146*

**Sample Collection**

*Date: 8/12/25*  
*Time: 10:31 AM*  
*Method: Grab*

*Matrix: Recreational Water*  
*Source Type: Pool*

**Sample Final Analysis**

*Date: 8/15/25*  
*Time: 9:00 AM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	2:56 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	10:31 AM	EH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/12/25	10:31 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:31 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*