



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 251

Customer

Facility Name: Penn Trafford High School

Address: 3381 Rt. 130
Harrison City, PA 15636

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 11/10/25

Time: 2:32 PM

Method: Grab

Sample Final Analysis

Date: 11/13/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/25	9:50 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25	9:50 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	11/10/25	2:32 PM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	11/10/25	2:32 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/10/25	2:32 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor