

Source Type:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 372

Customer Sample Collection Facility Name: Pine Richland H.S. Date: 8/4/25 Time: 12:01 PM Address: 700 Warrendale Rd. Method: Grab Gibsonia, PA 15044 Sample Final Analysis Matrix: Recreational Water Date: 8/7/25

Time: 11:20 AM
Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: 8/5/25 Absent Absent 9:20 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 8/5/25 9:20 AM AΗ SM 9222B 200/ml 3:10 PM AΗ Standard plate count: 0/ml 8/4/25 SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	12:01 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:01 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:01 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Source Type:

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 372

Customer Sample Collection Facility Name: Pine Richland H.S. Date: 8/4/25 Time: 12:01 PM Address: 700 Warrendale Rd. Method: Grab Gibsonia, PA 15044 Sample Final Analysis Matrix: Recreational Water Date: 8/7/25

Time: 11:20 AM
Deep End Analyst: AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: 8/5/25 Absent Absent 9:20 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 8/5/25 9:20 AM AΗ SM 9222B 200/ml 3:10 PM AΗ Standard plate count: 0/ml 8/4/25 SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	12:01 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	12:01 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	12:01 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor