



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2702

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Adams Ridge
Address: 100 Adams Ridge Blvd.
Mars, PA 16046

Date: 5/28/25
Time: 9:29 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 11:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 11:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/28/25 | 9:29 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:29 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:29 AM | ZR | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2702

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Adams Ridge
Address: 100 Adams Ridge Blvd.
Mars, PA 16046

Date: 5/28/25
Time: 9:29 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 5/31/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 5/29/25 | 11:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/29/25 | 11:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/28/25 | 6:25 PM | SL | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.4 SU | 7.2 - 7.8 SU | 5/28/25 | 9:29 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/28/25 | 9:29 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/28/25 | 9:29 AM | ZR | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor