Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# *2072*

Customer

			Sample Collection	
Facility Name:	*Camp Deer Creek*		*Date:*	*6/10/25*
			Time:	*3:15 PM*
Address:	*109 Eisele Road*		*Method:*	*Grab*
	Cheswick, PA 15024			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/13/25*
			Time:	*9:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	3:15 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	3:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	3:15 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2072

Customer

Facility Name:	*Camp Deer Creek*
Address:	*109 Eisele Road*
	Cheswick, PA 15024
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/10/25*
Time:	3:15 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/13/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	4:33 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/10/25	3:15 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/10/25	3:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	3:15 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor