

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2651

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Courtyards at Windsor Woods Clubhouse

Address: 4000 Sir James Dr.

McDonald, PA 15057

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 7/22/25 Time: 3:02 PM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B SL Standard plate count: 0/ml 200/ml 7/22/25 6:00 PM SM 9215B **Field Analysis** Results **Reporting limit** Date/Time **Analyst** Method pH: 7.8 SU 7.2 - 7.8 SU 7/22/25 3:02 PM AF DPD Chlorine: 1.0 - 5.0 mg/l 7/22/25 ΑF **DPD** 5.0 mg/l 3:02 PM 3:02 PM Turbidity: 1 NTU 1 - 2 NTU 7/22/25 ΑF Visual

Reporting limit

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2651

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Courtyards at Windsor Woods Clubhouse

Address: 4000 Sir James Dr.

McDonald, PA 15057

Matrix: Recreational Water

Results

Source Type: Pool

Accredited Analysis

Sample Collection

Date: 7/22/25 Time: 3:02 PM

Method: Grab

Sample Final Analysis

Incubation Date/Time

 Date:
 7/25/25

 Time:
 10:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B SL Standard plate count: 0/ml 200/ml 7/22/25 6:00 PM SM 9215B **Field Analysis** Results **Reporting limit** Date/Time **Analyst** Method pH: 7.8 SU 7.2 - 7.8 SU 7/22/25 3:02 PM AF DPD Chlorine: 1.0 - 5.0 mg/l 7/22/25 ΑF **DPD** 5.0 mg/l 3:02 PM 3:02 PM Turbidity: 1 NTU 1 - 2 NTU 7/22/25 ΑF Visual

Reporting limit

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith