

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address:

3113 Main Street Munhall, PA 15120

Matrix:

Recreational Water

Source Type:

Deep End

Sample Collection

Date: Time: 6/9/25 12:20 PM

Method: Grab

Sample Final Analysis

Date: Time: 6/12/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time		Method
pH:	8.0 SU	7.2 - 7.8 SU	6/9/25	12:20 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:20 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:20 PM	DW	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address:

3113 Main Street Munhall, PA 15120

Matrix:

Recreational Water

Source Type:

Deep End

Sample Collection

Date: Time: 6/9/25 12:20 PM

Method: Grab

Sample Final Analysis

Date: Time: 6/12/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time		Method
pH:	8.0 SU	7.2 - 7.8 SU	6/9/25	12:20 PM	DW	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:20 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:20 PM	DW	Visual

## Sample comments

andre Smith

( When exceeding reporting limit pool or spa is unfit)