



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 192**

**Customer**

Facility Name: John H. Linton Small  
Address: 250 Aster St.  
Penn Hills, PA 15235

**Sample Collection**

Date: 8/18/25  
Time: 9:45 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/21/25  
Time: 9:00 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Small Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	2:42 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/18/25	9:45 AM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/18/25	9:45 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	9:45 AM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor