



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2375

Customer
American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: OakHill - Wadsworth

Address: 480 Oak Hill Dr
Pittsburgh, Pa 15213

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/18/25

Time: 11:35 AM

Method: Grab

Sample Final Analysis

Date: 8/21/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	2:42 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/18/25	11:35 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/18/25	11:35 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	11:35 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor