



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# 328

Customer

Facility Name: Washington & Jefferson

Address: 60 S. Lincoln St.
Washington, PA 15301

Matrix: Recreational Water

Source Type: Dive Pool

Sample Collection

Date: 1/20/26

Time: 8:29 AM

Method: Grab

Sample Final Analysis

Date: 1/23/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/21/26	12:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/21/26	12:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/20/26	12:00 AM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	1/20/26	12:00 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	1/20/26	12:00 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/20/26	12:00 AM	GR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)