



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 087

Customer

Facility Name: Devonshire
Address: 1050 McNeilly Rd.
Pittsburgh, PA 15226

Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 8/25/25
Time: 12:44 PM
Method: Grab

Sample Final Analysis

Date: 8/28/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/26/25 11:15 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25 11:15 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25 5:50 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/26/25 11:20 AM	PS	SM 9230C
---------------------	----------	----------	------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	8/25/25 12:44 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/25 12:44 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25 12:44 PM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor