



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 355

Customer

Facility Name: YMCA - Butler
Address: 339 North Washington St.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/29/25
Time: 3:35 PM
Method: Grab

Sample Final Analysis

Date: 1/1/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/25	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/25	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/29/25	6:00 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/30/25	11:00 AM	EB	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/29/25	3:35 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/29/25	3:35 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/29/25	3:35 PM	BH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)