



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041  
**APM**

**Lab# 467**

C1

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Here Apts*  
  
*Address:*            *3506 Forbes Ave*  
                              *Pittsburgh, PA 15213*

**Sample Collection**

*Date:*                *10/8/25*  
*Time:*             *11:20 AM*  
*Method:*          *Grab*

*Matrix:*             *Recreational Water*  
  
*Source Type:*      *Spa*

**Sample Final Analysis**

*Date:*                *10/10/25*  
*Time:*             *5:30 PM*  
*Analyst:*           *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/8/25	3:30 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	10/8/25	5:40 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	10/8/25	11:20 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/8/25	11:20 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/8/25	11:20 AM	BH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

\_\_\_\_\_  
Andre Smith, Lead Supervisor