

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2228

 Customer
 Sample Collection

 Facility Name:
 Glennwood Condo
 Date: 7/29/25

 Time:
 12:42 PM

 Address:
 430 Cannongate Drive
 Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 8/1/25

Time: 9:00 AM

Source Type: Pool Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 | 9:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 | 9:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 | 3:40 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/29/25 | 12:42 PM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 | 12:42 PM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 | 12:42 PM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2228

 Customer
 Sample Collection

 Facility Name:
 Glennwood Condo
 Date: 7/29/25

 Time:
 12:42 PM

 Address:
 430 Cannongate Drive
 Method: Grab

Monroeville, PA 15146

Matrix: Recreational Water Sample Final Analysis

Date: 8/1/25

Time: 9:00 AM

Source Type: Pool Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/30/25 | 9:00 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/30/25 | 9:00 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/29/25 | 3:40 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 7/29/25 | 12:42 PM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 7/29/25 | 12:42 PM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/29/25 | 12:42 PM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor