



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2493**

**Customer**

Facility Name: Sonoma Ridge  
Address: 4007 Duckhorn Dr.  
Moon Township, PA 15108

**Sample Collection**

Date: 7/29/25  
Time: 11:00 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Baby Pool

**Sample Final Analysis**

Date: 8/1/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2493**

**Customer**

Facility Name: Sonoma Ridge  
Address: 4007 Duckhorn Dr.  
Moon Township, PA 15108

**Sample Collection**

Date: 7/29/25  
Time: 11:00 AM  
Method: Grab

Matrix: Recreational Water  
Source Type: Baby Pool

**Sample Final Analysis**

Date: 8/1/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	11:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/29/25	11:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	11:00 AM	VH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor