



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 062

Customer

Facility Name: *Comfort Inn - Butler*

Address: *1 Comfort Ln.
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *2/16/26*

Time: *3:25 PM*

Method: *Grab*

Sample Final Analysis

Date: *2/18/26*

Time: *11:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 2/17/26 | 11:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/17/26 | 11:00 AM | SL | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 2/16/26 | 5:08 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 2/16/26 | 3:25 PM | BH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 2/16/26 | 3:25 PM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/16/26 | 3:25 PM | BH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor