



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2716

**Customer**

Facility Name: *Traditions of America-Richland*

Address: *101 Patriot Lane  
Glenshaw, PA 15116*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *7/9/25*

Time: *3:01 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/12/25*

Time: *8:30 AM*

Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	6:20 PM	SL	SM 9215B

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Fecal Streptococcus	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9230C

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	7/9/25	3:01 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/9/25	3:01 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	3:01 PM	CW	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-16

Lab# 2716

**Customer**

Facility Name: *Traditions of America-Richland*

Address: *101 Patriot Lane  
Glenshaw, PA 15116*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *7/9/25*

Time: *3:01 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/12/25*

Time: *8:30 AM*

Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	6:20 PM	SL	SM 9215B

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Fecal Streptococcus	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9230C

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.6 SU	7.2 - 7.8 SU	7/9/25	3:01 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/9/25	3:01 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	3:01 PM	CW	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

---

Andre Smith, Lead Supervisor