Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2316

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	*Laurel Village*	*Date:*	*6/9/25*
		Time:	*8:25 AM*
Address:	*1000 Penn Center Blvd.*	*Method:*	*Grab*
	Pittsburgh, PA 15235		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/12/25*
		Time:	*9:30 AM*
Source Type:	*Deep End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	8:25 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:25 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:25 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2316

Customer	American Pools Management
	3261 Babcock Blvd.
	Pittsburgh, PA 15237

Sample Collection

Facility Name:	Laurel Village	Date:	6/9/25
		Time:	8:25 AM
Address:	1000 Penn Center Blvd.	Method:	Grab
	Pittsburgh, PA 15235		

Sample Final Analysis

Matrix:	Recreational Water	Date:	6/12/25
		Time:	9:30 AM
Source Type:	Deep End	Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	2:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/9/25	8:25 AM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/25	8:25 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	8:25 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor