



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2254

Customer

Facility Name: Hidden Valley Southridge

Address: 1900 S. Ridge Dr.
Hidden Valley, PA 15502

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 8/11/25

Time: 10:11 AM

Method: Grab

Sample Final Analysis

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	10:11 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:11 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:11 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 2254

Customer

Facility Name: Hidden Valley Southridge

Address: 1900 S. Ridge Dr.
Hidden Valley, PA 15502

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 8/11/25

Time: 10:11 AM

Method: Grab

Sample Final Analysis

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	10:11 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/11/25	10:11 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	10:11 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor