**Dream Pools and Spas**
**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-15**

*Lab#* **167**

## Customer

| | |
|---|---|
| *Facility Name:* | *Home 2 Suites* |
| *Address:* | *1401 Cranberry Woods Dr.* *Cranberry, PA 16066* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool* |

## Sample Collection

| | |
|---|---|
| *Date:* | *7/15/25* |
| *Time:* | 11:25 AM |
| *Method:* | *Grab* |

## Sample Final Analysis

| | |
|---|---|
| *Date:* | *7/18/25* |
| *Time:* | *9:30 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/16/25 | 10:50 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/16/25 | 10:50 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/15/25 | 4:20 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4  SU | 7.2 - 7.8 SU | 7/15/25 | 11:25 AM | ZR | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 7/15/25 | 11:25 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/15/25 | 11:25 AM | ZR | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

Lab ID No. 02-04041

**N-15**

*Lab#  167*

---

## *Customer*

| | |
|---|---|
| *Facility Name:* | *Home 2 Suites* |
| *Address:* | *1401 Cranberry Woods Dr. Cranberry, PA 16066* |
| *Matrix:* | *Recreational Water* |
| *Source Type:* | *Pool* |

## *Sample Collection*

| | |
|---|---|
| *Date:* | *7/15/25* |
| *Time:* | 11:25 AM |
| *Method:* | *Grab* |

## *Sample Final Analysis*

| | |
|---|---|
| *Date:* | *7/18/25* |
| *Time:* | *9:30 AM* |
| *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 7/16/25 | 10:50 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/16/25 | 10:50 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/15/25 | 4:20 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4  SU | 7.2 - 7.8 SU | 7/15/25 | 11:25 AM | ZR | DPD |
| Chlorine: | 0.5 mg/l | 1.0 - 5.0 mg/l | 7/15/25 | 11:25 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/15/25 | 11:25 AM | ZR | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

_____

Andre Smith, Lead Supervisor