



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 365

Customer

Facility Name: YMCA - Sewickley

Address: 625 Blackburn Rd.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/8/25
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 9/11/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|----------------|----|----------|
| Escherichia Coli: | Absent | Absent | 9/9/25 9:30 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/9/25 9:30 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/8/25 5:30 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/9/25 10:00 AM | SL | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|-----------------|-----|--------|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 9/8/25 11:00 AM | AMH | DPD |
| Chlorine: | 7.2 mg/l | 1.0 - 5.0 mg/l | 9/8/25 11:00 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/8/25 11:00 AM | AMH | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor