Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	*Nineteen North Apts*	*Date:*	6/10/25
		Time:	2:06 PM
Address:	*1050 Nineteen North Dr.*	*Method:*	*Grab*
	Pittsburgh, PA 15237		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/13/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	2:06 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25	2:06 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	2:06 PM	MM	Visual

Sample comments

Andre Smith (signature)

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2630

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	*Nineteen North Apts*	*Date:*	6/10/25
		Time:	2:06 PM
Address:	*1050 Nineteen North Dr.*	*Method:*	*Grab*
	Pittsburgh, PA 15237		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/13/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/10/25	2:06 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/10/25	2:06 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	2:06 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor