



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2219**

**Customer**

Facility Name: Garden City Swim Club

Address: 510 Garden City Dr.  
Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Deep End

**Sample Collection**

Date: 7/7/25

Time: 1:38 PM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	2/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	1:38 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:38 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:38 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 12**

**Lab# 2219**

**Customer**

**Facility Name:** Garden City Swim Club

**Address:** 510 Garden City Dr.  
Monroeville, PA 15146

**Matrix:** Recreational Water

**Source Type:** Deep End

**Sample Collection**

**Date:** 7/7/25

**Time:** 1:38 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 7/10/25

**Time:** 9:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	AH	SM 9222G
Total coliforms:	2/100mls	2/100mls	7/8/25	9:30 AM	AH	SM 9222B
Standard plate count:	5700/ml	200/ml	7/7/25	3:51 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/7/25	1:38 PM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:38 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:38 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor