



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 252

Customer

Facility Name: *Perry Traditional Academy*

Address: *3875 Perrysville Ave.
Pittsburgh, PA 15214*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *7/8/25*

Time: *1:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/11/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/9/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	7/9/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	D	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/8/25	1:15 PM	EJ	DPD
Chlorine:	1.5 mg/l	C	7/8/25	1:15 PM	EJ	DPD
Turbidity:	1 NTU	A	7/8/25	1:15 PM	EJ	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 252

Customer

Facility Name: Perry Traditional Academy

Address: 3875 Perrysville Ave.
Pittsburgh, PA 15214

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/8/25

Time: 1:15 PM

Method: Grab

Sample Final Analysis

Date: 7/11/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/9/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	7/9/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	D	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	7/8/25	1:15 PM	EJ	DPD
Chlorine:	1.5 mg/l	C	7/8/25	1:15 PM	EJ	DPD
Turbidity:	1 NTU	A	7/8/25	1:15 PM	EJ	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor