



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 181

Customer

Facility Name: Hyatt Regency Airport

Address: 1111 Airport Boulevard
Pittsburgh, PA 15231

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/26/25

Time: 1:48 PM

Method: Grab

Sample Final Analysis

Date: 8/29/25

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	300/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/26/25	1:48 PM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	1:48 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	1:48 PM	AMH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor