



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 135

Customer

Facility Name: *Hampton School District*

Sample Collection

Date: 9/24/25

Address: *2929 McCully Rd.
Allison Park, PA 15101*

Time: 1:00 PM

Method: Grab

Matrix: *Recreational Water*

Sample Final Analysis

Date: 9/26/25

Source Type: *Pool Shallow*

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/25	3:20 PM	SL SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/25	3:20 PM	SL SM 9222B
Standard plate count:	0/ml	200/ml	9/24/25	3:20 PM	SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/24/25	1:00 PM	VH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/24/25	1:00 PM	VH DPD
Turbidity:	1 NTU	1 - 2 NTU	9/24/25	1:00 PM	VH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor