



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 168

Customer

Facility Name: Home 2 Suites
Address: 8630 Duncan Ave.
Pittsburgh, PA 15237

Sample Collection

Date: 10/8/25
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 10/10/25
Time: 5:00 PM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 10/8/25 | 4:30 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 10/8/25 | 4:30 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 10/8/25 | 3:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 10/8/25 | 8:30 AM | VH | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 10/8/25 | 8:30 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 10/8/25 | 8:30 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor