



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 195

**Customer**

Facility Name: Kingley Assoc.  
Address: 6435 Frankstown Ave.  
Pittsburgh, PA 15206  
Matrix: Recreational Water  
Source Type: Pool -Deep

**Sample Collection**

Date: 8/11/25  
Time: 8:20 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/14/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	8:20 AM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	8:20 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	8:20 AM	LM	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 195

**Customer**

Facility Name: Kingley Assoc.  
Address: 6435 Frankstown Ave.  
Pittsburgh, PA 15206  
Matrix: Recreational Water  
Source Type: Pool -Deep

**Sample Collection**

Date: 8/11/25  
Time: 8:20 AM  
Method: Grab

**Sample Final Analysis**

Date: 8/14/25  
Time: 9:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	2:31 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/11/25	8:20 AM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	8:20 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	8:20 AM	LM	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor