

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041 S-14

Lab# 048

Customer

Facility Name: Chartiers Valley H.S.

50 Thoms Run Road Address:

Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Shallow End Sample Collection

Date: 8/4/25

Time: 10:56 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25 Time: 11:20 AM

Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/5/25 10:50 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 10:50 AM AS SM 9222B 8/5/25 Standard plate count: 0/ml 200/ml 8/4/25 4:55 PM AH SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/4/25 | 10:56 AM | AF | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 10:56 AM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 10:56 AM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041 S-14

Lab# 048

Customer

Facility Name: Chartiers Valley H.S.

50 Thoms Run Road Address:

Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Shallow End Sample Collection

Date: 8/4/25

Time: 10:56 AM

Method: Grab

Sample Final Analysis

Date: 8/7/25 Time: 11:20 AM

Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/5/25 10:50 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 10:50 AM AS SM 9222B 8/5/25 Standard plate count: 0/ml 200/ml 8/4/25 4:55 PM AH SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/4/25 | 10:56 AM | AF | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/4/25 | 10:56 AM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/25 | 10:56 AM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

andre Smith