



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 065

Customer

Facility Name: Wingate

Address: 106 Bair Blvd
New Stanton, PA 15672

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/27/25

Time: 8:42 AM

Method: Grab

Sample Final Analysis

Date: 5/30/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25	8:42 AM	JC
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/27/25	8:42 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	8:42 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 065

Customer

Facility Name: Wingate

Address: 106 Bair Blvd
New Stanton, PA 15672

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/27/25
Time: 8:42 AM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:45 AM	EB
Total coliforms:	0/100mls	2/100mls	5/28/25	9:45 AM	EB
Standard plate count:	0/ml	200/ml	5/27/25	5:40 PM	AS

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25	8:42 AM	JC
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	5/27/25	8:42 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	8:42 AM	Visual

Sample comments

A handwritten signature in black ink that reads "Andre Smith". The signature is fluid and cursive, with "Andre" on the first line and "Smith" on the second line.

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor