



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2382

Customer

Facility Name: Orchard Park
Address: 100 Macintosh Ct.
Cranberry Twp, PA 16066
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 6/9/25
Time: 12:00 PM
Method: Grab

Sample Final Analysis

Date: 6/12/25
Time: 9:30 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB
Standard plate count:	570/ml	200/ml	6/9/25	2:51 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:00 PM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:00 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:00 PM	ZR

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2382

Customer

Facility Name: Orchard Park
Address: 100 Macintosh Ct.
Cranberry Twp, PA 16066
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 6/9/25
Time: 12:00 PM
Method: Grab

Sample Final Analysis

Date: 6/12/25
Time: 9:30 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:15 AM	EB
Total coliforms:	0/100mls	2/100mls	6/10/25	9:15 AM	EB
Standard plate count:	570/ml	200/ml	6/9/25	2:51 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/9/25	12:00 PM	ZR
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	12:00 PM	ZR
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	12:00 PM	ZR

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".