



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 2131

Customer

Facility Name: Cork Factory
Address: 2349 Rail Road St.
Pittsburgh, PA 15222
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/27/25
Time: 10:30 AM
Method: Grab

Sample Final Analysis

Date: 8/30/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/28/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/28/25	10:40 AM	AS	SM 9222B
Standard plate count:	300/ml	200/ml	8/27/25	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/27/25	10:30 AM	BH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/27/25	10:30 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/25	10:30 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor