



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 416**

**Customer**

Facility Name: Drury Hotel  
Address: 101 Ridge Rd.  
Pittsburgh, PA 15205

**Sample Collection**

Date: 7/8/25  
Time: 9:15 AM  
Method: Grab

Matrix: Recreational Water

Source Type: Spa

**Sample Final Analysis**

Date: 7/11/25  
Time: 9:00 AM  
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |                |    |          |
|-----------------------|----------|----------|----------------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 7/9/25 9:00 AM | EB | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 7/9/25 9:00 AM | EB | SM 9222B |
| Standard plate count: | 200/ml   | 200/ml   | 7/8/25 3:28 PM | AH | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                 |    |          |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/9/25 11:00 AM | AH | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |                |    |        |
|------------|----------|----------------|----------------|----|--------|
| pH:        | 7.4 SU   | 7.2 - 7.8 SU   | 7/8/25 9:15 AM | VH | DPD    |
| Chlorine:  | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 9:15 AM | VH | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 7/8/25 9:15 AM | VH | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 416**

**Customer**

**Facility Name:** Drury Hotel  
**Address:** 101 Ridge Rd.  
Pittsburgh, PA 15205

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 7/8/25  
**Time:** 9:15 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/11/25  
**Time:** 9:00 AM  
**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |                |    |          |
|-----------------------|----------|----------|----------------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 7/9/25 9:00 AM | EB | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 7/9/25 9:00 AM | EB | SM 9222B |
| Standard plate count: | 200/ml   | 200/ml   | 7/8/25 3:28 PM | AH | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                 |    |          |
|---------------------|----------|----------|-----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 7/9/25 11:00 AM | AH | SM 9230C |
|---------------------|----------|----------|-----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |                |    |        |
|------------|----------|----------------|----------------|----|--------|
| pH:        | 7.4 SU   | 7.2 - 7.8 SU   | 7/8/25 9:15 AM | VH | DPD    |
| Chlorine:  | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 9:15 AM | VH | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 7/8/25 9:15 AM | VH | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor