



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2554

Customer

Facility Name: *Village of Shadyside*

Address: *100 Denniston Ave.*
Pittsburgh, Pa 15206

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/7/25*
Time: *9:05 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 | 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 | 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/7/25 | 3:41 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/7/25 | 9:05 AM | LM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 9:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 9:05 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2554

Customer

Facility Name: *Village of Shadyside*

Address: *100 Denniston Ave.*
Pittsburgh, Pa 15206

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/7/25*
Time: *9:05 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/10/25*
Time: *9:30 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 9:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 9:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/7/25 3:41 PM | AH | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|----------------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/7/25 9:05 AM | LM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/7/25 9:05 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 9:05 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor