



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2242

Customer

Facility Name: Hawthorne Commons
Address: 214 Sycamore Dr.
Seven Fields, PA 16046

Sample Collection

Date: 8/27/25
Time: 3:19 PM
Method: Grab

Sample Final Analysis

Date: 1/0/00
Time: 12:00 AM
Analyst: 1/0/00

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/28/25 10:40 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/28/25 10:40 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/27/25 5:40 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/27/25 3:19 PM | SL | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 8/27/25 3:19 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/27/25 3:19 PM | SL | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor