Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2378

Customer			*Sample Collection*	
Facility Name:	*Oakmont C.C.*		*Date:*	7/8/25
			Time:	2:50 PM
Address:	*1233 Hulton Road*		*Method:*	*Grab*
	Oakmont, PA 15139			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	7/11/25
			Time:	9:00 AM
Source Type:	*Baby Pool*		*Analyst:*	AS

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	EB	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	2:50 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **2378**

Customer

Facility Name:	Oakmont C.C.
Address:	1233 Hulton Road Oakmont, PA 15139
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	7/8/25
Time:	2:50 PM
Method:	Grab

Sample Final Analysis

Date:	7/11/25
Time:	9:00 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	5:35 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/8/25	2:50 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/8/25	2:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	2:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor