



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 346

Customer

Facility Name: Woodlands Camp
Address: 134 Shenot Road
Wexford, PA 15090

Sample Collection

Date: 1/28/26
Time: 10:15 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 1/31/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/29/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/29/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/28/26	4:55 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	1/28/26	10:15 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	1/28/26	10:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/28/26	10:15 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor